

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2303369-0  
**Report Reference** EX28471-20210713  
**Date** 17-Mar-2023

**Issued to:** Ningjin APC Industries Incorporated Company  
18 OF TAISHAN RD NINGJIN, SHANDONG 253400  
China

**This is to certify that representative samples of** VLTR7 - Accessories for Special Systems Certified for Canada  
See Addendum Page for Product Designation(s).

UL-CA-2303369-0

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ULC/ORD C260, 1st Ed., Issue Date: 1975-02-28

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

EX28471-20210713

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2303369-0  
**Report Reference** EX28471-20210713  
**Date** 17-Mar-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
CFU190525N, maximum working pressure 350 psi. For use in releasing water or air pressure from the control trim of special-system water-control valves deluge type automatically, when actuated by electrical detectors or remote control. Electrical ratings: 220V/110V, 50/60Hz, 18W.	Electrically operated solenoid valves

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2303837-0  
**Report Reference** EX28471-20210713  
**Date** 17-Mar-2023

**Issued to:** Ningjin APC Industries Incorporated Company  
18 OF TAISHAN RD NINGJIN, SHANDONG 253400  
China

**This is to certify that  
representative samples of**

VLTR - Accessories for Special Systems  
See Addendum Page for Product Designation(s).

UL-US-2303837-0

Have been evaluated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 260, 7th Ed., Issue Date: 2004-3-17, Revision Date:  
2018-7-3, UL 429, 7th Ed., Issue Date: 2013-11-6, Revision  
Date: 2021-3-19, UL 521, Edition 7, Issue Date 1999-02-19,  
Revision Date 2022-07-26, UL Subject 429A, 4th Ed., Issue  
Date: 2021-3-30

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

EX28471-20210713

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2303837-0  
**Report Reference** EX28471-20210713  
**Date** 17-Mar-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
CFU190525N, maximum working pressure 350 psi. For use in releasing water or air pressure from the control trim of special-system water-control valves deluge type automatically, when actuated by electrical detectors or remote control. Electrical ratings: 220V/110V, 50/60Hz, 18W.	Electrically operated solenoid valves

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

