Instruction Manual

VDOT-STB-RL Relay Base



Before Installation

Please read these instructions carefully and keep for future reference.

The information in this document is subject to change without notice. For updates please refer to our website.

A CAUTION

Do not use the products outside the rated power supply voltage range specified in the Specifications. It may cause a fire or damage to equipment.

⚠ CAUTION

Do not disassemble, repair, or modify the products. It may cause a fire or electric shock.

∴ CAUTION

Make sure to turn the power off before commencing any wiring work. Otherwise it may cause electric shock or damage to equipment.

Note: Follow the requirements for the installation of the products in accordance with the Specifications. Otherwise it may cause damage to equipment.

Note: Do not install the product in any location where oil, dust, iron powder, chemicals, or hydrogen sulphide may occur or affect the product. It may cause damage to equipment.

Section 1 - INTRODUCTION

VDOT-STB-RL is a detector base with relay output for use with Zeta Control Panel series, which is designed for use with an addressable detector. When a detector is in alarm condition, the base receives a control signal from the detector, which has the relay operate. The rating of contact is DC30V/1A.

Section 2 - TERMINALS

VDOT-STB-RL base is supplied with 2 terminals as standard, along with a relay output terminal block of C form contact.

The terminals of VDOT-STB-RL base are configured as follows:

- -Terminal 1 = SLC positive
- -Terminal 6 = SLC negative
- -Terminal 3 = No connection
- Relay terminal block with N/O, N/C, and COM




Figure 1: Position of terminals

Section 3 – DIMENSIONS




Figure 2: Dimension of VDOT-STB-RL

Section 4 – DETECTOR MODELS

VDOT-STB-RL Base is available for use with the VDOT series detectors. It is important to use the correct detector for each application. The standard range of detectors available is as follows:

Model	Description	Instruction Manual
VDOT-PY	Analog addressable photoelectric smoke detector	GLT-299-7-1
VDOT-PYH	Analog addressable combination photoelectric smoke and heat detector 57°C (135° F) with 8.3°C (15°F) rate of rise	GLT-299-7-4
VDOT-H2	Analog addressable heat detector 57° C (135° F) with 8.3°C(15°F) rate of rise	GLT-299-7-2
VDOT-DPH	Analog addressable combination photoelectric smoke (dual wave length) and heat detector 57° C (135° F) with 8.3° C(15° F) rate of rise	GLT-299-7-5

Optional accessory

VDOT-ADP adapter: Use this adapter when VDOT-STB-RL is installed with a 4" square electrical box or 4" octagonal electrical box. (Refer to "VDOT-ADP Instruction Manual" for details.)

Section 5 - INSTALLATION

The product must be installed in accordance with the applicable NFPA standards, local codes and jurisdictional authorities. Failure to follow these instructions may result in failure of the detector to report an alarm condition.

Note: ZETA ALARMS LIMITED is not responsible for the product which is improperly installed, maintained and tested.

Note: Use the VDOT-ADP adapter for a 4" square electrical box or 4" octagonal electrical box. VDOT-ADP adaptor is not used for a 3-1/2" octagonal electrical box.




Figure 3: Installation to an electrical box

Section 6 - CONNECTIONS

Install wiring in accordance with Figure 4 in this document.

All wiring must conform to applicable local codes, ordinances, and regulations.




Figure 4: Connection to Zeta control panel series

A CAUTION

Use cable AWG12-20 for SLC terminals, and cable AWG14-22 for relay terminals. Do not connect different gauge cables at one terminal in order to prevent loosening.

Do not connect cables in reverse polarity. Failure to connect the polarity correctly could result in damage to the base and/or other equipment.




Figure 5: Connection to terminals

For system monitoring - for terminals 1 and 6, do not use looped wire under terminals. Break wire run to provide monitoring of connections.

Before installing the product check the continuity, polarity and insulation resistance of all wiring. Check that siting is in accordance with the site system drawings and conforms to all applicable local codes such as NFPA 72.

In normal use, the **VDOT-STB-RL** base will be installed at ceiling level. Pass the field wiring through the cable hole in the center and from the rear of the base. Hold and affix the base to the ceiling or electrical box with screws via the base mounting holes. Connect the field wiring to the base terminals, as detailed in Section 5 and 6,

4

Mar 23, 2018

making sure the wiring does not obstruct fitting of the detector head.

Fit the detector head by inserting it into the base and turning clockwise until the notch in the detector rim aligns with base locking screws. To avoid unauthorized de-installation, turn the locking screw counterclockwise until the screw comes to about 4mm(3/16") from the rim of the base, as shown in Figure 6. The OMNIVIEWTM 360° indicator permits visibility from any angle.




Figure 6: Position of locking screw

Note: Smoke and heat detectors are not to be used with detector guards unless the combination has been evaluated and found suitable for that purpose.

Section 7 - MAINTENANCE

Maintenance

The **VDOT-STB-RL** is a high quality product engineered for reliability. In order to obtain optimum performance, periodic maintenance is required, at lease in accordance with NFPA 72 chapter 14 "Inspection, Testing and Maintenance".

Routine Inspection:

Ensure the detector head and the base are secure and undamaged.

Operation Test:

The purpose of the Operational Test is to confirm the product's correct operation.

- 1) When carrying out site testing of the product, the control panel shall be set to "one-man-walk test mode" prior to the test.
- 2) Take any necessary precautions to limit the sounding of the alarm sounders/bells and any fire service summoning device.

3) Operate the detector in accordance with each detector's instruction manual as mentioned in Section 4. Check that the LED indicator on the detector illuminates. When the detector goes into an alarm status, confirm that the output relay of the product is in operation (close between N/O and COM, open between N/C and COM).



Please note that the output relay operates if the detector is in operation even though in the "one-man-walk test mode". Take appropriate measures depending on the situation in the field.

Note: If the test cannot be carried out by operating the detector, remove the detector and short between terminal 3 and 6 to check the relay switches.

4) After the detector has given the alarm condition, the detector is automatically reset by control panel. It may be necessary to allow a short time to elapse before resetting the detector.

Confirm that the output relay goes back to the initial status (open between N/O and COM, close between N/C and COM) after the detector is reset.

Note: For detector testing and cleaning information, refer to each detector's instruction manual as mentioned in Section 4.

Section 8 - SPECIFICATIONS

SLC Applied Voltage	Rated Range 20VDC to 38VDC	
SLC Current Consumption	Standby 24µA Alarm/Activated 110µA	
SLC Line impedance	Up to 50ohms, 2km(1.24mile) (Refer to * below)	
RELAY	Switching capacity DC 30V/1A resistive	
UL Ambient Installation Temperature	0°C (32° F) to 38°C (100° F)	
Operating Temperature	-10°C (14° F) to 55°C (131° F)	
Storage Temperature	-20°C (-4° F) to 60°C (140° F)	
Max Relative Humidity	Up to 95% RH, non-condensing	
Environment	Indoor dry use only	
Terminal	Terminal for SLC: AWG12 to 20	
Terriira	Terminal for Relay: AWG14 to 22	
Dimensions	φ105 mm x 22.5 mm H (φ4.133" x 0.885" H)	
Difficusions	(Mount to a 3-1/2" octagonal box)	
Weight	Approximately 79g (2.8 ounces)	
Standard	UL268 and UL521	

^{*} Refer to the Installation and Operation Manual of Zeta Control Panel series to determine correct loop load and maximum loop resistance for devices connected to each loop.

FOR WARRANTY SERVICE, RETURN TO:

ZETA ALARMS LIMITED

72-78 MORFA ROAD, SWANSEA, SA1 2EN

http://www.zetaalarmsystems.com

Section 9 - WARRANTIES

1.1 Zeta warrants to the customers that:

(a) all products supplied hereunder will be of merchantable quality and will comply with any specification agreed between Zeta and customer.

(b) it is not aware of any rights of any third party in the market which would or might render the sale of the

products, or the use of any of the trade marks on or in products, or the use of any of the trade marks on or in

relation to the products, unlawful.

1.2 In the event of any breach of the Zeta's warranty in Clause 1.1(a) whether by reason of defective materials,

production faults or otherwise, Zeta's liability shall be limited to:

(a) replacement of the products in question; or

(b) at the Zeta's option, repayment of the price where this had been paid.

And the warranty period is three (3) years from the shipment from Zeta's factory.

1.3 Notwithstanding anything to the contrary in this warranty terms, Zeta shall not be liable to the customer by

reason of any representation or implied warranty, condition or other term or any duty at common law, or

under the express terms of this warranty terms, for any consequential lossor damage whether for loss of

profit or otherwise and whether occasioned by the negligence of Zeta or its employees or agents or

otherwise, arising out of or in connection with any act or omission of Zeta relating to Zeta or supply of the

products, their use by any customer.

1.4 Customer shall indemnify Zeta against all loss, damages, liabilities, costs and expenses which Zeta may

suffer or incur as a result of or in connection with any breach by customer of this warranties terms or any laws

or regulations of any jurisdiction or any rules of any governing authorities.

GLT-299-7-9 Rev. 0 Mar 23, 2018

7