

BRE Global

Notified Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2523

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

XFP501/CA 1 Loop 32 Zone Analogue Addressable Control and Indicating Equipment using CAST protocol, metal housing

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Computationics Limited (Trading as C-TEC)
Challenge Way
Martland Mill Industrial Estates
Wigan, Lancashire
WN5 0LD
United Kingdom

Computationics Limited (Trading as C-TEC)
Challenge Way
Martland Mill Industrial Estates
Wigan, Lancashire
WN5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment and EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 24 June 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Eman Mattie-Suleiman, Technical Development
Director,
On behalf of BRE Global Limited

Date of First Issue: 24 June 2019

Date of Issue: 24 June 2019

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2523**XFP501/CA 1 Loop 32 Zone Analogue Addressable Control and Indicating Equipment using CAST protocol, metal housing**

Incorporating the following modules:

SPF0050110 1 Loop Main board
SPF0501021 Switch mode power supply board
SPF0501199 Display Board

Certified with the following options with requirements from EN 54-2: 1997

7.8 Output to fire alarm devices
7.11 Delays to outputs
7.12.1 Dependencies on more than one alarm signal – Type A
7.12.2 Dependencies on more than one alarm signal – Type B
7.12.3 Dependencies on more than one alarm signal – Type C
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of addressable points
10 Test condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.



Eman Mattie-Suleiman, Technical Development Director,

On behalf of BRE Global Limited

Date of First Issue: 24 June 2019

Date of Issue: 24 June 2019

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.