

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoIRIS WS
Description: Intelligent analogue addressable fire alarm wall sounder and strobe

Complies to the following standards:

EN 55032:2015
EN 50130-4:2011/A1:2014
EN 54-3:2001+A1:2002+A2:2006
EN 54-17:2005/AC:2007

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EC – EMC
2014/35/EC – LVD
2011/65/EU – RoHS

Additional information:

First date of production: 11.2013

Certificate:

№1293–CPR-0404 Rev. 1 of August 11, 2017 from Notified body № 1293 EVPU

Test report:

№ 00152/2014/C of April 15, 2014 from Notified body № 1293 EVPU

№ 90024/2014 of March 28, 2014 from Notified body № 1293 EVPU

Note: Sounder SensoIRIS WS is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP54

1407 Sofia,
14A, Srebarna Str.
23.11.2017

Yuliy Iliev
Quality Manager

