

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoIRIS WSST IS

Description: Intelligent analogue addressable fire alarm sounder with built-in isolator module

Complies to the following standards:

EN 55032:2015
EN 50130-4:2011
EN 54-3:2001+A1:2002+A2:2006
EN 54-17:2005/AC:2007
EN 54-23:2010

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EC - EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 11.2013

Certificate:

№1293–CPR-0462 Rev.1
№ 00031/101/1/2015
№ 1139d/01

of August 10, 2017 from Notified body № 1293 EVPU
of January 29, 2015 from Notified body № 1293 EVPU
of October 13, 2016 from Notified body № 0832 LPCB

Test report:

№ 00511/2014/C
№ TE-E123439-1000

of January 29, 2015 from Notified body № 1293 EVPU
of October 13, 2016 from Notified body № 0832 LPCB

Note: Sounder SensoIRIS WSST IS is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP65

1407 Sofia,
14A, Srebarna Str.
23.11.2017

Yuliy Iliev
Quality Manager

