

Date of Issue –20th September 2018

EU DECLARATION OF CONFORMITY

1. Object of the Declaration of Conformity:

Product Family: XP95 Detectors

Part Number	Brand	Product Description
55000-400	XP95 Heat	A2S Heat Detector
55000-401	XP95 Heat	CS High Temperature Heat Detector
55000-420	XP95 Heat	A2S Heat Detector - VdS / EMC
55000-430	XP95 Heat	A2S Heat Detector
55000-440	XP95 I.S. Heat	Heat Detector
55000-500	XP95 Ion	Ionisation Smoke Detector
55000-520	XP95 Ion	Ionisation Smoke Detector
55000-560	XP95 Ion	Ionisation Smoke Detector
55000-600	XP95 Optical	Optical Smoke Detector
55000-620	XP95 Optical	Optical Smoke Detector- EMC
55000-630	XP95 Optical	Optical Smoke Detector
55000-640	XP95 I.S. Heat	Optical Smoke Detector
55000-660	XP95 Optical	Optical Smoke Detector – Black
55000-885	XP95 Multisensor	Multisensor Smoke Detector

- These products are manufactured at the premises of Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR.
- This declaration is issued under the sole responsibility of the manufacturer.
- The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

2014/30/EU EMC Directive
2011/65/EU Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

A HALMA COMPANY



Assessed to ISO 9001:2008
LPCB Cert No. 010



Certificate No. 010
See www.RedBookLive.com



Assessed to ISO 14001:2004
Certificate number EMS 010

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB339 055354

5. References to the relevant harmonized standards used or references to the specifications in relation to which conformity is declared:

BS EN 61000-6-3: 2007+A1: 2011 Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments

BS EN 50130-4:2011+A1: 2014 Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

This declaration is made for and on behalf of Apollo Fire Detectors by the Technical Director, Mr. Karl Westhead, who has been designated as the responsible person for the purpose of the Regulations.



SignatureMr. Karl Westhead – Technical Director