



## EC DECLARATION OF PERFORMANCE

According to EU Construction Products Regulation No. 305/2011

1. Unique Product Identification Code(s): M700KAC
2. Type Number(s):
  - M700KAC-[xx]

Where

  - Sx = surface mount;
  - Fx = flush mount;
  - xF = Flexible element
  - xG = Glass element

Description: Manual Call Point.
3. Intended Use: Fire detection and fire alarm systems installed in and around buildings
4. Manufacturer:
 

KAC Alarm Company  
KAC House  
Thornhill Road  
North Moons Moat  
Redditch  
B98 9ND  
UK
5. Trading Company:
 

Notifier by Honeywell  
(Pittway Systems Technology Group (Europe) Ltd)  
Caburn House  
2B Brooks Road  
LEWES  
BN7 2BY
6. System of assessment: System 1
7. Notified Body: BRE Global Ltd
 

Notified Body Number: 0832

EC Certificate Number(s) 0832-CPR-F1747
8. European Technical Assessment Reference: Not Applicable
9. Declared Performance:

EN 54-11: Fire Detection and Fire Alarms Systems – Manual Call points		
Clause	Essential Characteristic	Performance
4.1.	Compliance	Pass
4.2.	Marking and data	Pass
4.3.	Frangible element	Pass
4.4.	Indicators for alarm condition	Pass
4.5.	Reset facility	Pass
4.6.	Test facility	Pass
4.7.	Construction and design	Pass – Type A
4.8.	Additional requirements for software controlled manual call points	Pass
5.1.	General	Pass
5.2.	Operational performance	Pass
5.3.	Function	Pass
5.4.	Test facility	Pass
5.5.	Reliability	Pass
5.6.	Variation of supply	Pass
5.7.	Dry heat (operational)	Pass
5.8.	Dry heat (endurance)	Pass
5.9.	Cold (operational)	Pass
5.10.	Damp heat cyclic (operational)	Pass
5.11.	Damp heat cyclic (endurance)	Pass
5.12.	Damp heat steady state (endurance)	Pass
5.13.	Sulphur dioxide (SO2) corrosion (endurance)	Pass
5.14.	Shock (operational)	Pass
5.15.	Impact (operational)	Pass
5.16.	Vibration, sinusoidal (operational)	Pass





5.17	Vibration, sinusoidal (endurance)	Pass
5.18	Electromagnetic compatibility (EMC) (operational)	Pass
5.19	Enclosure protection	Pass

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

For and on behalf of  
KAC Alarm Company Ltd

KAC Alarm Company  
KAC House  
Thornhill Road  
North Moons Moat  
Redditch  
B98 9ND  
UK

Name  
Title

McNAMARA  
Director  
MAR 2017

**KAC Alarm Company Limited**  
KAC House  
Thornhill Road  
North Moons Moat  
Redditch  
B98 9ND