

## DECLARATION OF CONFORMITY

*We,* **Teletek Electronics JSC**  
*Address:* 14A, Srebarna Str.  
1407 Sofia, Bulgaria

*Declares that the*

*Product:* **SensoIRIS M140 IS**  
*Description:* Addressable combined heat and smoke detector with built-in isolator module

*Complies to the following standards:*

**EN 54-5:2000/A1:2002**  
**EN 54-7:2000/A1:2002/A2:2006**  
**EN 54-17:2005+AC:2007**  
**EN 55032:2015**  
**EN 50130-4:2011/A1:2014**

*The following Regulation:*

**CPR № 305/2011**  
**REACH No 1907/2006**

*And the following Directives:*

**2014/30/EU - EMC**  
**2011/65/EU – RoHS II**

**Additional information:**

*First date of production:* 03.2018

*Certificate:*

№ 0832-CPR-F2634 of March 28, 2019 from Notified body № 0832 LPCB

*Test Report:*

№ TE-P110102-1001 Issue 1 of March 28, 2019 from Notified body № 0832 LPCB  
№ SW-P110102-1001 Issue 1 of January 08, 2019 from Notified body № 0832 LPCB

*Note:* To be used in conjunction with the base B124

1407 Sofia,  
14A, Srebarna Str.  
31.05.2019

Yuliy Iliev  
Quality Manager

