

## Declaration of performance

№ 054/2017

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

**IRIS (0) Repeater P**  
**IRIS (0) Repeater M**

2. *Type Number:*

**IRIS (0) Repeater P**  
**IRIS (0) Repeater M**

*Description:*

**Addressable Fire Alarm Control Panel**

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

**Fire detection and fire alarm systems installed in and around buildings**

4. *Manufacturer*

**Teletek Electronics JSC**  
**14A Srebarna Str.**  
**1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC**  
**14A Srebarna Str.**  
**1407 Sofia, Bulgaria**

6. *System of assessment*

**System 1**

7. *Notified Body*

**BRE Global Limited**  
**Bucknalls Lane, Garston, Watford,**  
**Hertfordshire, United Kingdom WD25 9XX**

*Notified Body Number*

**0832**

*Performed* **the prescribed tests and evaluation of factory production control according to system 1 and issued the following certificate**

*EC Certificate Number*

**1139h/R01**

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

<b>EN 54-2:1997 + AC:1999 + A1:2006 - Fire detection and fire alarm systems - Part 2: Control and indicating equipment</b>		
<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonized technical specification</b>
Performance under fire conditions	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Response delay (response time to fire)	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Operational reliability	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Temperature resistance	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Vibration resistance	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Electrical stability	Pass	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability: humidity resistance	Pass	EN 54-2:1997 + AC:1999 + A1:2006

<b>EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006 - Fire detection and fire alarm systems - Part 4: Power supply equipment</b>		
<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonized technical specification</b>
Performance of power supply	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Operational reliability	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability, Temperature resistance	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability, Vibration resistance	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability, Electrical stability	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability: humidity resistance	Pass	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,  
14A, Srebarna Str.  
01.06.2017

Yuliy Iliev  
Quality Manager

