

## Certificate of Product Approval

Certificate Number: 126bp

Issue: 03

### Siemens Switzerland Ltd

Theilerstrasse 1a  
CH-6300 Zug  
Switzerland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Line Units

FT2001-A1

FT2010-A1

FT2011-A1

FT2010-C1

(refer to Appendix for details)

#### Standards

EN 54-17:2005

EN 54-18:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

26 June 2023

Date of Issue

30 July 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. And is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

## Appendix to Certificate No: 126bp

Issue: 03

### Siemens Switzerland Ltd

| Certified Product | Description                                                                                                                                                                                | LPCB Ref.No. |
|-------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|
| FT2001-A1         | Digital Addressable Mimic Display Driver (F50F410, 520379)<br>Note 1: Approved when used with a metal enclosure at least complying with protection class IP30 and weighing at least 4.5kg. | 126bp/01     |
| FT2010-A1         | Floor Repeater Terminal                                                                                                                                                                    | 126bp/02     |
| FT2011-A1         | Floor Repeater Display                                                                                                                                                                     | 126bp/03     |
| FT2010-C1         | Floor Repeater Terminal with Flat Rear Panel                                                                                                                                               | 126bp/04     |

### Accessories:

F50F410 LED flat cable  
520379 AC/AC Transformer

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

26 June 2023

Date of Issue

30 July 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre