

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0) 1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F0392

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Apollo Auto-Aligning Beam Detector and System Controller

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

and produced in the manufacturing plant(s):

FFE Ltd
9 Hunting Gate
Wilbury Way, Hitchin
Hertfordshire
SG4 0TJ
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-12:2015 - Smoke detectors - Line detectors using an optical light beam

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 22 November 2013 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 22 November 2013

Date of Issue: 09 April 2019

Issue number 03

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

**BRE Global Limited**

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F0392**Apollo Auto-Aligning Beam Detector and System Controller****Ancillaries:**

0020-017 – Mounting Bracket
29650-070 – Second Detector Head

Sensitivities:

Sensitivity setting from 25% to 35% only
Delay to fire setting between 2 and 20 seconds only

Notes:

1. Apollo model 29650-069, approved range 8-50m with a single reflector (reflector part. No. 23901.01)
2. Apollo model 29600-526 reflector extension kit, approved range 50-100m
3. 29650-069 approved for use with 1-2 heads

P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 22 November 2013

Date of Issue: 09 April 2019

Issue number: 03

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.