



This is to certify that: Kentec Electronics Limited

Unit 25-27 Dartford Trade Park

Fawkes Avenue

Questor Dartford DA1 1JQ

United Kingdom

Holds Certificate Number: KM 96761

In respect of:

BS EN 54-2, BS EN 54-4 & BS EN 12094-1

Control and Indicating Equipment and Power Supply Equipment, Electrical Automatic Control and Delay Devices for Gas Extinguishing Systems

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 1 of 7

...making excellence a habit."



No. KM 96761

BS EN 12094-1:2003, BS EN 54-2:1997 and BS EN 54-4:1998 + A1.

Sigma XT series

| Model Reference | Туре |
|------------------------|--|
| K11031M2 | Class A, Single area Fire Extinguishing Control Panel Surface mounting |
| K11031F2 | Class A, Single area Fire Extinguishing Control Panel Flush mounting |

Certified for use with Apollo, Fulleon, Hochiki, Nittan, Notifier and MorleyIAS System Sensor and KAC fire Detection and alarm products and MTL7778ac and MTL5561 intrinsically safe barriers.

The Sigma XT is certified when fitted with Swedish Keyswitch.

The Sigma XT is also suitable for use with the following units:

| Model Reference | Туре |
|-----------------|---|
| K911000M8 | 6 lamp status unit surface |
| K911000F8 | 6 lamp status unit flush |
| K911100M8 | 6 lamp status unit with mode select keyswitch surface |
| K911100F8 | 6 lamp status unit with mode select keyswitch flush |
| K911010M8 | 6 lamp status unit with manual release surface |
| K911010F8 | 6 lamp status unit with manual release flush |
| K911110M8 | 6 lamp status unit with mode select keyswitch and manual release surface |
| K911110F8 | 6 lamp status unit with mode select keyswitch and manual release flush |
| W911000W8 | IP65 - 6 lamp status unit surface |
| W911100W8 | IP65 - 6 lamp status unit surface with mode select keyswitch surface |
| W911110W8 | IP65 - 6 lamp status unit with mode select keyswitch and manual release surface |
| K91000M10 | Extinguishant hold off switch unit - green button |
| KB91000M10 | Extinguishant hold off switch unit - red button |

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 2 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated online.

No. KM 96761

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997

Output to fire alarm devices (clause 7.8) Delays to outputs (clause 7.11) Test condition (clause 10)

Certified with the following options with requirements from BS EN 12094-1:2003

Delay of extinguishing signal (clause 4.17)
Signal representing the flow of extinguishing agent (clause 4.18)
Monitoring of the status of components (clause 4.19)
Emergency hold device (clause 4.20)
Control of flooding time (clause 4.21)
Manual only mode (clause 4.23)
Triggering signals to equipment within the system (clause 4.24)
Triggering signals to equipment outside the system (clause 4.26)
Activation of alarm devices with different signals (clause 4.30)

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 3 of 7

No. KM 96761

BS EN 12094-1:2003, BS EN 54-2:1997 + A1:2006 and BS EN 54-4:1997 + A1:2003 & A2:2006.

Sigma XT+ series

| Model Reference Type | |
|---|--|
| K21001M2 Class A, Single area extinguishing control unit | |
| K21021M3 Class A, Two zone, single area extinguishing control panel | |
| K21041M3 Class A, Four zone, single area extinguishing control panel | |
| K21042M3 Class A, Four zone, two area extinguishing control panel | |
| K21081M3 Class A, Eight zone, single area extinguishing control panel | |
| K21082M3 Class A, Eight zone, two area extinguishing control panel | |
| K21083M4 Class A, Eight zone, three area extinguishing control panel | |
| K21084M4 Class A, Eight zone, four area extinguishing control panel | |

Certified for use with Apollo series 30, 60 & 65, Fulleon, Hochiki, Nittan, Notifier and MorleyIAS ECO1000, KAC fire detection and alarm products and MTL7778ac and MTL5561 intrinsically safe barriers.

The Sigma XT+ is certified when fitted with Swedish Keyswitch.

The Sigma XT+ is also suitable for use with the following units:

| Model Reference | Туре |
|-----------------|--|
| K911000M8 | 6 lamp status unit surface |
| K911000F8 | 6 lamp status unit flush |
| K911100M8 | 6 lamp status unit with mode select keyswitch surface |
| K911100F8 | 6 lamp status unit with mode select keyswitch flush |
| K911010M8 | 6 lamp status unit with manual release surface |
| K911010F8 | 6 lamp status unit with manual release flush |
| K911110M8 | 6 lamp status unit with mode select keyswitch and manual release surface |
| K911110F8 | 6 lamp status unit with mode select keyswitch and manual release flush |
| W911000W8 | IP65 - 6 lamp status unit surface |
| W911100W8 | IP65 - 6 lamp status unit surface with mode select keyswitch surface |
| | |

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 4 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated online.

No. KM 96761

| Model Reference | туре |
|-----------------|---|
| W911110W8 | IP65 - 6 lamp status unit with mode select keyswitch and manual release surface |
| K91000M10 | Extinguishant hold off switch unit - green button |
| KB91000M10 | Extinguishant hold off switch unit - red button |

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997

Output to fire alarm devices (clause 7.8) Delays to outputs (clause 7.11) Test condition (clause 10)

Certified with the following options with requirements from BS EN 12094-1:2003

Delay of extinguishing signal (clause 4.17) Signal representing the flow of extinguishing agent (clause 4.18) Monitoring of the status of components (clause 4.19) Emergency hold device (clause 4.20) Control of flooding time (clause 4.21) Manual only mode (clause 4.23) Triggering signals to equipment outside the system (clause 4.26) Emergency abort device (clause4.27) Activation of alarm devices with different signals (clause 4.30)

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 5 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated online.

No. KM 96761

BS EN 12094-1:2003, BS EN 54-2:1997 + A1:2006 and BS EN 54-4:1997 + A1:2003 & A2:2006

Syncro XT+ K31000 & K32000 Series

| Model Reference | Туре |
|------------------------|---|
| A31161M3 | Class A, 1 loop, 1 Area Extinguishant Control Panel |
| A32161M3 | Class A, 2 loop, 1 Area Extinguishant Control Panel |
| A31162M3 | Class A, 1 loop, 2 Area Extinguishant Control Panel |
| A32162M3 | Class A, 2 loop, 2 Area Extinguishant Control Panel |
| A31163M4 | Class A, 1 loop, 3 Area Extinguishant Control Panel |
| A32163M4 | Class A, 2 loop, 3 Area Extinguishant Control Panel |
| A31164M4 | Class A, 1 loop, 4 Area Extinguishant Control Panel |
| A32164M4 | Class A, 2 loop, 4 Area Extinguishant Control Panel |
| H31161M3 | Class A, 1 loop, 1 Area Extinguishant Control Panel |
| H32161M3 | Class A, 2 loop, 1 Area Extinguishant Control Panel |
| H31162M3 | Class A, 1 loop, 2 Area Extinguishant Control Panel |
| H32162M3 | Class A, 2 loop, 2 Area Extinguishant Control Panel |
| H31163M4 | Class A, 1 loop, 3 Area Extinguishant Control Panel |
| H32163M4 | Class A, 2 loop, 3 Area Extinguishant Control Panel |
| H31164M4 | Class A, 1 loop, 4 Area Extinguishant Control Panel |
| H32164M4 | Class A, 2 loop, 4 Area Extinguishant Control Panel |
| V31161M3 | Class A, 1 loop, 1 Area Extinguishant Control Panel |
| V32161M3 | 2 loop, 1 Area Extinguishant Control Panel |
| V31162M3 | Class A, 1 loop, 2 Area Extinguishant Control Panel |
| V32162M3 | Class A, 2 loop, 2 Area Extinguishant Control Panel |
| V31163M4 | Class A, 1 loop, 3 Area Extinguishant Control Panel |
| | |

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 6 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated online.

No. KM 96761

Model Reference Type

V32163M4 Class A, 2 loop, 3 Area Extinguishant Control Panel
V31164M4 Class A, 1 loop, 4 Area Extinguishant Control Panel
V32164M4 Class A, 2 loop, 4 Area Extinguishant Control Panel

Certified for use with Apollo, Hochiki, and Argus Vega fire detection and alarm products

Prefix A = Apollo Protocol, H = Hochiki Protocol & V = Argus Vega Protocol

The following Sigma Si status units are compatible for use with the K31000 & K32000 models in Table 1:

K911000M8 6 lamp status unit surface

K911000F8 6 lamp status unit flush

K911100M8 6 lamp status unit with mode select keyswitch surface

K911100F8 6 lamp status unit with mode select keyswitch

K911010M8 6 lamp status unit with manual release surface

K911010F8 6 lamp status unit with manual release flush

K911110M8 6 lamp status unit with mode select keyswitch and manual release surface

K911110F8 6 lamp status unit with mode select keyswitch and manual release flush

W911000W8 IP65 - 6 lamp status unit surface

W911100W8 IP65 - 6 lamp status unit surface with mode select keyswitch surface

W911110W8 IP65 - 6 lamp status unit with mode select keyswitch and manual release surface

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997

Output to fire alarm devices (clause 7.8) Delays to outputs (clause 7.11) Test condition (clause 10)

Certified with the following options with requirements from BS EN 12094-1:2003

Delay of extinguishing signal (clause 4.17) – up to 60 seconds

Signal representing the flow of extinguishing agent (clause 4.18)

Monitoring of the status of components (clause 4.19)

Emergency hold device (clause 4.20)

Control of flooding time (clause 4.21)

Manual only mode (clause 4.23)

Triggering signals to equipment outside the system (clause 4.26)

Emergency abort device (clause4.27)

Activation of alarm devices with different signals (clause 4.30)

First Issued: 19/10/2005 Latest Issue: 15/12/2015

Page: 7 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 845 080 9000. An electronic certificate can be authenticated online.