



Procedure:	EC DECLARATION OF PERFORMANCE		
Document No:	DOP0038	Issue No:	1
Form:	KAC826-01	Date:	29/4/14
Approved By:	William Nock (QA Manager)		

## According to EU Construction Products Regulation No. 305/2011

1. Unique Product Identification Code(s): CWST

Type Number(s):
 CWST-[a][b]- [c][d]

Where:

[a] indicates body colour
[b] indicates flash colour
[c] indicates base option
[d] indicates first or second fix

Description: Audio Visual devices.

Intended Use: Detection and alarm systems installed in and around buildings

4. Manufacturer: KAC Alarm Company Limited

KAC House, Thornhill Road,

North Moons Moat, Redditch, B98 9ND, UK

5. Trading Company: KAC Alarm Company Limited

KAC House, Thornhill Road,

North Moons Moat, Redditch, B98 9ND, UK

6. System of assessment: System 1

7. Notified Body: LPCB – BRE

**Bucknalls Lane** 

Garston Watford WD25 9XX

Notified Body Number: 0832

EC Certificate Number(s) CWST-xW-x5 - 0832-CPR-F0257

CWST-xW-x6 - 0832-CPR-F0257 CWST-xR-x5 - 0832-CPR-F0258 CWST-xR-x6 - 0832-CPR-F0258

8. European Technical Assessment

Reference:

Not Applicable

9. Declared Performance:

EN54-23: Fire Detection and Fire Alarm Systems – Visual Alarm Devices				
Clause	Description	Performance		
4.1	General	Pass		
4.2	Operational reliability	Pass		
4.3	Performance parameters under fire conditions	Pass		
4.4	Durability	Pass		
5.1	General	Pass		
5.2	Operational reliability	Pass		
5.3	Performance parameters under fire conditions	Pass		
5.4	Durability	Pass		





Procedure:	EC DECLARATION OF PERFORMANCE		
Document No:	DOP0038	Issue No:	1
Form:	KAC826-01	Date:	29/4/14
Approved By:	William Nock (QA Manager)		

We hereby declare that the product identified above meets the requirements of the following EC Directives and therefore qualify for free movement within markets comprising the European Union (EU) and the European Economic Area (EEA):-

## Conforms to:

- EMC Directive 2004/108/EC
- Low Voltage Directive (LVD) 2006/95/EC
- RoHS Directive 2011/65/EU

## **Approved Accessories: -**

SC076 = 5x Earth Strap,

SC077 = 5x Terminal Block,

SC078 = 5x Installer Link,

PS188 = 5x Deep Base O-Ring,

PS189 = 5x Deep Base Gasket,

CSR = 5x Shallow Base-Red,

CSW = 5x Shallow Base-White,

CWW=5x IP65 Deep Base-White,

CWR = 5x IP65 Deep Base-Red.

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacture identified below.

For and on behalf of KAC Alarm Company.

William Nock (Quality Manager)

----

DATE:29/4/14

KAC Alarm Company Limited KAC House, Thornhill Road, North Moons Moat, Redditch, B98 9ND, UK