

## DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011  
N° 004 - CPR - 2013

1. *Unique Product identification code:*  
**NFS2, NFS4, NFS8, NFS8V**
2. *Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):*

<b>Two Zone Conventional Fire Alarm Control Panel</b>	<b>NFS2</b>
<b>Four Zone Conventional Fire Alarm Control Panel</b>	<b>NFS4</b>
<b>Eight Zone Conventional Fire Alarm Control Panel</b>	<b>NFS8</b>
<b>Eight Zone Conventional Fire Alarm Control Panel GmbH</b>	<b>NFS8V</b>
3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:*  
**Fire detection and fire alarm systems installed in buildings.**
4. *Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):*  
**Notifier by Honeywell  
(Pittway Systems Technology Group Europe Ltd)  
Manufactured by:  
Honeywell Life Safety Systems  
140 Waterside Road  
Hamilton Industrial Estate  
Leicester  
LE5 1TN  
UNITED KINGDOM**
5. *Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):*  
**Not Applicable**
6. *System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*  
**System 1**
7. *In case of the declaration of performance concerning a construction product covered by the harmonized standard:*  
**VdS Schadenverhütung**  
*performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:*  
**0786-CPD-20797**
8. *In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:*  
**Not applicable, see item 7**

9. Declared Performance:


All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below:

Essential characteristics	Performance	Harmonized Technical Specification	
		EN 54-2: 1997 + A1: 2006	EN 54-4: 1997 + A2: 2006
Operational reliability	Pass	Art.: 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14	Art.: 4, 5, 6, 7, 8
Durability of operational reliability Temperature resistance	Pass	Art.: 15.4	Art.: 9.5
Durability of operational reliability Vibration resistance	Pass	Art.: 15.6, 15.7, 15.15	Art.: 9.7, 9.8, 9.15
Durability of operational reliability Electrical stability	Pass	Art.: 15.8 to 15.13	Art.: 9.9 to 9.13
Durability of operational reliability Humidity resistance	Pass	Art.: 15.5, 15.14	Art.: 9.6, 9.14
Performance under fire conditions	Pass	Art.: 4, 5, 7	
Response delay (response time to fire)	Pass	Art.: 7.1, 7.7, 7.11, 7.12	
Performance of power supply	Pass		Art.: 4, 5, 6

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:

Name and Function..... MARK AYTON..... M.D.....

Signature:  .....

Date: 20-6-13 .....