

## Certificate of Product Approval

Certificate Number: 010an

Issue: 06

### Apollo Fire Detectors Limited

36 Brookside Road,  
Havant,  
Hampshire,  
P09 1JR,  
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Flame Detectors

55000-022	55000-063
55000-023	55000-064
55000-024	55000-065
55000-025	55000-019
55000-020	55000-021
55000-060	55000-061
55000-280	55000-062
55000-295	

#### Standards

EN 54-10:2002 + A1:2005

(refer to Appendix for details)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Steve Patrick  
Verifier

20 January 2015  
Date of Issue

29 April 2010  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 010an Apollo Fire Detectors Limited

Issue: 06

Certified Product	Description	LPCB Ref.No.
55000-022	XP95 Intelligent UV Flame Detector (45681-209 and 45681-210) Note: Meets EN 54-10:2002 at Class 1 and Class 3	010an/01
55000-023	XP95 Intelligent UV/IR <sup>2</sup> Flame Detector (45681-209 and 45681-210) Note: Meets EN 54-10:2002 at Class 1 and Class 3	010an/02
55000-024	XP95 Intelligent IR <sup>3</sup> Flame Detector (45681-209 and 45681-210) Note: Meets EN 54-10:2002 at Class 1 and Class 3	010an/03
55000-025	S65 Conventional UV Flame Detector (45681-200 and 45681-201) Note: Meets EN 54-10:2002 at Class 1 and Class 3	010an/04
55000-019	Conventional IR <sup>3</sup> Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/05
55000-060	Conventional IR <sup>2</sup> Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/06
55000-061	Conventional IR <sup>2</sup> (Exd) Flameproof Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/07
55000-062	Conventional IR <sup>3</sup> (Exd) Flameproof Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/08
55000-063	Conventional IR <sup>3</sup> Intrinsically Safe Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/09
55000-064	Conventional UV/IR <sup>2</sup> Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/10
55000-065	Conventional UV/IR <sup>2</sup> (Exd) Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/11

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Steve Patrick  
Verifier

20 January 2015  
Date of Issue

29 April 2010  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**

## Appendix to Certificate No: 010an Apollo Fire Detectors Limited

Issue: 06

Certified Product	Description	LPCB Ref.No.
55000-020	Analogue Addressable IR <sup>3</sup> Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/13
55000-021	Analogue Addressable IR <sup>3</sup> (Exd) Flameproof Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/14
55000-280	Analogue Addressable IR <sup>2</sup> Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/15
55000-295	Analogue Addressable IR <sup>2</sup> (Exd) Flameproof Flame Detector (29600-203) Note: Meets EN 54-10:2002 at Class 1 only	010an/16

### Products Extras

45681-200	Mounting base
45681-201	Mounting base with diode
45681-209	Deep base
46681-210	Mounting base
29600-203	Adjustable Mounting bracket

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Steve Patrick  
Verifier

20 January 2015  
Date of Issue

29 April 2010  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**