



EU Declaration of Conformity



CFP Conventional Fire Panels

Product Model Designation(s) & Description(s)

- CFP702E-4 CFP Economy 2 Zone Panel *
- CFP704E-4 CFP Economy 4 Zone Panel *
- CFP708E-4 CFP Economy 8 Zone Panel *
- CFP702-4 CFP Standard 2 Zone Panel *
- CFP704-4 CFP Standard 4 Zone Panel *
- CFP708-4 CFP Standard 8 Zone Panel *
- CFP702-4/R CFP Standard 2 Zone Panel, Red Housing *
- CFP704-4/R CFP Standard 4 Zone Panel, Red Housing *
- CFP708-4/R CFP Standard 8 Zone Panel, Red Housing *
- CFP702-2 CFP Alarmsense Two Wire 2 Zone Panel *
- CFP704-2 CFP Alarmsense Two Wire 4 Zone Panel *
- CFP704-2 CFP Alarmsense Two Wire 8 Zone Panel *
- CFP760 CFP 8 Zone Repeater Panel

Manufactured by C-TEC at:

Computationics Ltd (Trading as C-TEC) Challenge Way, Martland Park, Wigan, WN5 0LD, United Kingdom

are in conformity with the provisions of the following EU Directive(s):

- 2014/30/EU: Electromagnetic Compatibility Directive (EMC)
- 2014/35/EU: Low Voltage Directive (LVD)
- 2011/65/EU: Restriction of Use of certain Hazardous Substances Directive (RoHS)

Note: the products marked with an asterisk (*) are also in conformity with the Construction Products Regulation (CPR) for which a separate Declaration of Performance (DoP) is provided and may be obtained by emailing marketing@c-tec.co.uk

The products to which this declaration relates have been tested to and are in conformity with the following standards:

- EN 50130-4: 2011+A1:2014
Alarm Systems – Part 4: Electromagnetic Compatibility - Product family standard: Immunity requirements for components of fire, intruder and social alarm systems.
- EN 61000-6-3: 2007+A1:2011
Electromagnetic compatibility (EMC) – Part 6-3: Generic Standards - Emission standard for residential, commercial and light-industrial environments.
- EN 62368-1:2014
Audio/Video, Information & Communication Technology Equipment — Safety — Part 1: Safety Requirements
- BS EN IEC 63000:2018 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

In addition, the products satisfy the essential requirements of the following standards:

- EN54-2: 1997 + A1:2006
Fire detection and fire alarm systems – Control and indicating equipment
- EN54-4: 1997 + A1:2002 + A2:2006
Fire detection and fire alarm systems – Power supply equipment

Empowered Signatory of Company

I, the undersigned, hereby declare on behalf of Computationics Limited that the products listed above comply with the requirements of the standards listed above which gives presumption of conformity with the essential requirements of the directives listed above.

Name: Daniel Foster **Place:** Wigan, UK **Position:** Head of Science

Signature:

Date: 08/07/2022