BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F4442

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade and produced in the manufacturing plant(s):

mark of:

Kentec Electronics Ltd
Units 25-26 Fawkes Avenue

Kentec Electronics Ltd
Units 25-26 Fawkes Avenue

Questor Questor Questor

Dartford, Kent DA1 1JQ DA1 1JQ

DA1 1JQ

DA1 1JQ

United Kingdom United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment,

EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment,

EN 12094-1:2003 - Components for gas extinguishing systems - Requirements and test methods for electrical automatic control and delay devices

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 30 September 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 30 September 2020

Eman Mattie-Suleiman, Certification Engineer Date of Issue: 30 September 2020

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0 Page 1 of 3 © BRE Global Assurance (Ireland) Limited, 2020

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4442

Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d)

Incorporating the following modules:

S2022 Mainboard

S406 5.25 Amp Power Supply Unit

S420 2 Amp Power Supply Unit

The Sigma ZXT has different part numbers which are details below:

K192311XM2 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Standard Enclosure, 2A PSU

K192311XM3 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Large Enclosure, 2A PSU

K195311XM3 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Large Enclosure, 5A PSU

K192312XM2 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Standard Enclosure, 2A PSU, Nordic Key Switch

K192312XM3 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Large Enclosure, 2A PSU, Nordic Key Switch

K195312XM3 Conventional 3 Zone Control and Indicating Equipment & 1 Flooding Zone Class A Extinguishant Control Panel (e.c.d), Large Enclosure, 5A PSU, Nordic Key Switch

Certified with the following Options with requirements from EN 54-2:1997

7.8 Output to fire alarm devices

7.11 Delays to outputs

10 Test condition

Certified with the following Options with requirements from EN 12094-1:2003

4.17 Delay of extinguishing signal

4.18 Signal representing the flow of extinguishing agent

4.19 Monitoring of the status of components

4.20 Emergency hold device

4.21 Control of flooding time

4.23 Manual mode only

4.25 Extinguishing signals to spare cylinders

Date of First Issue: 30 September 2020

Eman Mattie-Suleiman, Certification Engineer, Date of issue: 30 September 2020

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0

Page 2 of 3

© BRE Global Assurance (Ireland) Limited, 2020

BRE Global Ireland

Notified Body No. 2831

www.breglobalireland.ie

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344 E: enquiries@breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4442

- 4.27 Emergency abort device
- 4.30 Activation of alarm devices with different signals

Notes:

- 1. Scope of certification does not include the operation of the network functionality.
- 2. This certificate does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
- 3. The Sigma ZXT is certified with the M2 (standard) & M3 (large) enclosure
- 4. The S420 PSE can be fitted in either a M2 or M3 cabinet. The S406 can only be fitted in a M3 cabinet.
- 5. Sigma ZXT can contain 2 different key switches which are referenced in the model numbers as below: K192311X '1X' denotes standard key

K192312X '2X' denotes Nordic key

Eman Mattie-Suleiman, Certification Engineer,

Date of First Issue: 30 September 2020

Date of issue: 30 September 2020

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0 Page 3 of 3 © BRE Global Assurance (Ireland) Limited, 2020