



EU Declaration of Conformity



Sigma ZXT

Kentec Electronics Limited declares that the products listed below conform to the essential requirements of the Low Voltage Directive 2014/35/EU and EMC Directive 2014/30/EU and are manufactured at an ISO9001 and ISO14001 certified facility. This declaration of conformity is issued under the sole responsibility of the manufacturer.

Place of manufacture: Kentec Electronics Limited
Units 25-26
Fawkes Avenue
Questor
Dartford Kent DA1 1JQ

Product Description:

K192311XM2 Sigma ZXT, 3 Zone Single Area Extinguishant Control Panel, Standard Enclosure, 2A PSU
K192311XM3 Sigma ZXT, 3 Zone Single Area Extinguishant Control Panel, Large Enclosure, 2A PSU
K195311XM3 Sigma ZXT, 3 Zone Single Area Extinguishant Control Panel, Large Enclosure, 5A PSU

Standards

EN12094-1:2003	Fixed firefighting systems. Components for gas extinguishing systems. Requirements and test methods for electrical automatic control and delay devices
EN54-2:1997 +A1:2006	Fire detection and fire alarm systems – Control and indicating equipment
EN54-4:1997 +A1:2002 +A2:2006	Fire detection and fire alarm systems – Power supply Equipment
EN62368-1: 2018	Audio/video, information and communication technology equipment safety requirements
EN61000-6-3:2007:+A1:2011	Electromagnetic compatibility (EMC) Generic standards. Emission standard for residential, commercial and light-industrial environments. Emissions, Class B.
BS EN 50130-4:2011+A1:2014	Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

See separate Declaration of Performance for Construction Products Regulation No. 305/2011.

Authorised by:

Ray Turner
Compliance Director

Issued: 20/12/2020
Dartford, England

Kentec Electronics Limited, Unit 25-26, Fawkes Avenue, Questor, Dartford, Kent DA1 1JQ
Telephone 01322 222121 Fax 01322 291794 www.kentec.co.uk