

Declaration of performance

№ 089/2019

According to Construction Products Regulation EU № 305/2011

1. Unique identification code of the product-type:

SensoMAG S30

2. Type Number:

SensoMAG S30

Description:

Optical smoke detector

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer

Fire detection and fire alarm systems installed in and around buildings

4. Manufacturer

Teletek Electronics JSC 14A Srebarna Str. 1407 Sofia, Bulgaria

5. Trading Company

Teletek Electronics JSC 14A Srebarna Str. 1407 Sofia, Bulgaria

6. System of assessment

System 1

7. Notified Body

EVPU a.s. 19 Trencianska Str. 018 51 Nova Dubnica, Slovakia

Notified Body Number

1293

EC Certificate Number

1293- CPR-0637

8. No European Technical Assessment has been issued for this product.

Page 1 of 2



9. Declared performance

| Essential characteristics | Performance | Harmonized technical specification EN 54-7:2000/A1:2002/ A2:2006 |
|---|-------------|--|
| Nominal activation conditions/Sensitivity, | Pass | 4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18 |
| Response delay (response time) and Performance under fire conditions | 1 | |
| 2 Part 1997 | | |
| Operational reliability | Pass | 4.2 to 4.7, 4.9 to 4.11 |
| Tolerance to supply voltage | Pass | 5.5 |
| Durability of operational reliability and | Pass | 5.8, 5.9 |
| response delay; temperature resistance | | 32 |
| Durability of operational reliability; | Pass | 5.13 to 5.16 |
| vibration resistance | | |
| Durability of operational reliability; | Pass | 5.10, 5.11 |
| humidity resistance | | South and the state of the stat |
| Durability of operational reliability; | Pass | 5.12 |
| corrosion resistance | | |
| Durability of operational reliability; | Pass | 5.17 |
| electrical stability | | |

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia, 14A, Srebarna Str. 01.04.2019 Yuliy Iliev

Quality Manager