

# UL-EU CERTIFICATE

**Certificate No.** UL-EU-01112-CPR  
**Page** 1/3  
**Date of Issue** 2019-05-30  
**Date of Re-issue** 2023-07-20

**Certificate Holder** Inim Electronics s.r.l,  
Via Dei Lavoratori 10  
Frazione Centobuchi  
63076 Montepandone (Ap)  
Italy

**Manufacturer** As per certificate holder

**Certified Product Type** Smoke detectors - Point detectors using scattered light,  
transmitted light or ionization for fire detection and fire  
alarm systems for buildings.

Heat detectors - Point detectors for fire detection and fire  
alarm systems for buildings

<b>Product Trade Name</b>	ID100	Conventional Optical Smoke Detector
	ID200	Conventional Heat Detector
	ID300	Conventional Multicriteria Detector
	EB0010	Detector Mounting Base



**Authorized Certification Decision Maker**  
Richard Bristow

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



# UL-EU CERTIFICATE

**Certification Mark** UL-EU mark  
**Certificate No.** UL-EU-01112-CPR  
**Page** 2/3  
**Date of Issue** 2019-05-30  
**Date of Re-issue** 2023-07-20

**Trademark**



**Rating/Classification** 10 - 30 V DC  
ID200 / ID300 - Heat Detection Class A1R and Class B  
*Note: Class A2S and Class BR are **not** certified.*

**Harmonised Technical Specifications** EN54-5:2017 + A1:2018  
EN54-7:2018

**Supporting Documentation** S36176-D02-EUROPEAN DIRECTIVE-ORIGINAL  
**Additional information**  
**Expiry date** 2029-05-29



# Appendix UL-EU Certificate

<b>Certification Mark</b>	<b>UL-EU mark</b>
<b>Certificate No.</b>	UL-EU-01112-CPR
<b>Page</b>	3/3
<b>Date of Issue</b>	2019-05-30
<b>Date of Re-issue</b>	2023-07-20

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

## PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at [www.ul.com](http://www.ul.com).

