

CERTIFICATE OF COMPLIANCE

Certificate Number EX28931
Report Reference EX28931-20230728
Date 2023-July-31

Issued to: Ningjin APC Industries Incorporated Company
18 OF TAISHAN RD
NINGJIN SHANDONG 253400 CN

This is to certify that representative samples of VALVES, ALARM
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: See addendum page for Standards

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX28931
Report Reference EX28931-20230728
Date 2023-July-31

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Standards:

Standard	Title
UL 193	Standard for Alarm Valves for Fire-Protection Service
ULC/ORD -C193-75	Guide for the Investigation of alarm valves for fire-protection service
UL 753	Alarm Accessories for Automatic Water-Supply Control Valves for Fire Protection Service
ULC-ORD- C753	Guide for the Investigation of Alarm Accessories for Automatic Water-Supply Control Valves for Fire Protection Service

Models:

Alarm valve, variable and constant pressure type, SSBJ-300GG, SSBJ-300FF, SSBJ-300FGA, SSBJ-300FGB

+ May incorporate the use of Model ZSFZ-YCQ-00 Retard Chamber, maximum rated pressure 300 psig for variable pressure service.

F - Flanged

G - Grooved

V - Vertical orientation

* End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.



Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

