



By Appointment to  
Her Majesty The Queen  
Manufacturers of Fire Detection & Alarm Products  
Apollo Fire Detectors Limited  
Hampshire



**Construction Products Regulation:  
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

**DECLARATION OF PERFORMANCE**

**No. 2531-CPR-CSP10946**

**1. Unique identification code of the product-type:**

**Model number and Description:**

58000-700 Discovery Analogue Addressable Multisensor Detector  
58000-700SIL Discovery Analogue Addressable Multisensor Detector

**Approved Accessories:**

45681-210 – XP95 Mounting Base  
45681-209 – XP95/Discovery Standard Deep Mounting Base

**Harmonised Product Type(s):**

Heat Detectors – Point Detectors  
Smoke Detectors – Point Detectors

**2. Intended use/es:**

Fire detection and fire alarm systems

**3. Manufacturer:**

Apollo Fire Detectors Ltd,  
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

**4. Authorised representative:**

N/A

**5. System of AVCP**

System 1

**6a. Harmonised Standard(s)**

EN 54-5:2000 + A1:2002  
EN 54-7:2000 + A1:2002 + A2:2006

**6b. Notified Body:**

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY



**Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

[www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Apollo Fire Detectors Ltd. Registered in England No. 1483208  
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

## 7. Declared performance

<b>Essential Characteristics</b>	<b>Standard EN 54-5: 2000 + A1:2002</b>	<b>Performance</b>
Nominal activation conditions/Sensitivity. Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6,5.8,6.1,6.2	Pass
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability and response delay: temperature resistance	5.9,5.10	Pass
Durability of operational reliability: vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability: humidity resistance	5.11, 5.12	Pass
Durability of operational reliability: corrosion resistance	5.13	Pass
Durability of operational reliability: electrical resistance	5.18	Pass

<b>Essential Characteristics</b>	<b>Standard EN 54-7:2000 + A1:2002 + A2:2006</b>	<b>Performance</b>
Nominal activation conditions/Sensitivity. Response delay (response time) and Performance under fire conditions	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	Pass
Operational reliability	4.2 to 4.7, 4.9 to 4.11	Pass
Tolerance to supply voltage	5.5	Pass
Durability of operational reliability and response delay: temperature resistance	5.8, 5.9	Pass
Durability of operational reliability: vibration resistance	5.13 to 5.16	Pass
Durability of operational reliability: humidity resistance	5.10,5.11	Pass
Durability of operational reliability: corrosion resistance	5.12	Pass
Durability of operational reliability: electrical resistance	5.17	Pass

The performance of the product identified above is in the conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole  
responsibility of the manufacturer identified above



8. **Online Display Location**

This document can be viewed online at [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. Karl Westhead  
Technical Director

Place and Date of Issue: Havant - 16 October 2019

(v4)

