

CERTIFICATE OF COMPLIANCE

Certificate Number 20121030-E192508
Report Reference E192508-19981029
Issue Date 2012-OCTOBER-30

Issued to: SIGNAL COMMUNICATIONS CORP
PO BOX 2588
WOBURN MA 01888

**This is to certify that
representative samples of**

FIRE ALARM DEVICES FOR USE IN HAZARDOUS
LOCATIONS


Fire alarm/initiation, Model SGX-32, for use in Class I,
Groups B, C and D; Class II, Groups E, F and G; Class III
hazardous locations, Type 4X enclosure. Complementary
Listed, UCCM (Signal and Fire Alarm Equipment, Marine)
(Boxes, Manually Activated, Marine) boxes, Non-Coded,
Marine.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203 STANDARD FOR EXPLOSION-PROOF AND
DUST-IGNITION-PROOF ELECTRICAL EQUIPMENT FOR
USE IN HAZARDOUS (CLASSIFIED) LOCATIONS

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

