

CERTIFICATE OF COMPLIANCE

Certificate Number S36437
Report Reference S36437-20220331
Date 2023-March-10

Issued to: Ningjin APC Industries Incorporated Company
18 OF TAISHAN RD
NINGJIN SHANDONG 253400 CN

**This is to certify that
representative samples of** EXTINGUISHING SYSTEM ATTACHMENTS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Waterflow Indicators for Fire Protective Signaling Systems,
UL 346, and CAN/ULC-S548, DEVICES AND
ACCESSORIES FOR WATER TYPE EXTINGUISHING
SYSTEMS

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number S36437
Report Reference S36437-20220331
Date 2023-March-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Fire Alarm Equipment:

Wet-pipe sprinkler system attachments: Waterflow Indicators (paddle-type), models ZSJZ-YM-450, ZSJZ-YM-450, ZSJZ-YM-450, ZSJZ-YM-450, ZSJZ-YM-450, ZSJZ-YM-450, ZSJZ-YM-450



Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>